

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7165-1703:145

Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Gamewell-FCI, 12 Clintonville Road, Northford CT 06472
Contact: Brian Carlson (781) 471-3000 FAX (781) 471-3099
Brian.carlson@honeywell.com

DESIGN: Identiflex 602, Models IF 602-126, IF 602-252, IF 602-126XL, IF 602-252XL, IF 602SS-198R, IF 602SS-396R, IF 602SS-198XL, and IF 602SS-396XL analog/addressable fire alarm control panel.

Identiflex IF 602VE, Models IF 602VE-126, IF 602VE-252 IF 602VE-126Z, and IF 602VE-252Z analog/addressable fire alarm control panel with voice evacuation. Used in conjunction with Model ACC-25/50 (ZS) series (CSFM Listing No. 6911-0075:207).

Local, auxiliary, remote station (reverse polarity), central station, releasing device, automatic, manual, waterflow and sprinkler supervisory services. Refer to the listee's data sheet for detailed product description and operational considerations. System components:

IF-602	Main Board
UDACT 610	Digital Communicator
LP-864	Line Protector
SID	Solenoid Interface Device
RSM-95	Remote Solenoid Module
31057	Power Supply
31077	City Tie Card
31078	RS-232 Optical Isolator Module
31079	Analog/addressable loop Class "A" Card
31086	LCD Display Board
30996*	Network Card
30997*	Fiber Optic Module

RATING: 120 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation instructions Manual for details.

These control units do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required the control unit must be used with audible appliances that can generate the temporal pattern signal.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE:

1. For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

2. Formerly 7165-1288:164

*Rev. 04-11-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 17, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division